



**Sales and
Service**

Lubricant Analysis Report

North America: +1-866-211-7420

0	1	2	3	4
NORMAL		ABNORMAL	CRITICAL	

Overall report severity based on comments.

Account Information		Component Information		Sample Information	
Account Number: [REDACTED] Company Name: [REDACTED] Contact: [REDACTED] Address: [REDACTED] Phone Number: [REDACTED]		Component ID: [REDACTED] Secondary ID: [REDACTED] Component Type: UNIDENTIFIED ENGINE Manufacturer: Information Requested Model: Information Requested Application: POWER GENERATION Sump Capacity:		Tracking Number: [REDACTED] Lab Number: [REDACTED] Lab Location: Salt Lake City Data Analyst: ZXH Sampled: 2024 Received: 06-May-2024 Completed: 09-May-2024	
Filter Information		Miscellaneous Information		Product Information	
Filter Type: Information Requested Micron Rating: 0				Product Manufacturer: Information Requested Product Name: Information Requested Viscosity Grade: Information Requested	
Comments	Flagged data does not indicate an immediate need for maintenance action. Continue to observe the trend and monitor equipment and fluid conditions. Base number is flagged, however without complete lubricant information, the starting point for this lubricant cannot be determined. In order to properly compare data to the correct standards, please provide COMPONENT MANUFACTURER and MODEL, and the FLUID MANUFACTURER, PRODUCT NAME, and VISCOSITY GRADE. Please provide this units sump capacity with next sample. Please specify diesel, natural gas, liquid petroleum gas, unleaded gasoline or gasoline engine.				

	Wear Metals (ppm)										Contaminant Metals (ppm)			Multi-Source Metals (ppm)						Additive Metals (ppm)				
Sample #	Iron	Chromium	Nickel	Aluminum	Copper	Lead	Tin	Cadmium	Silver	Vanadium	Silicon	Sodium	Potassium	Titanium	Molybdenum	Antimony	Manganese	Lithium	Boron	Magnesium	Calcium	Barium	Phosphorus	Zinc
1	16	1	0	4	1	2	1	0	0	0	6	4	9	0	1	0	0	0	50	750	1274	0	724	795

Sample Information								Contaminants			Fluid Properties					
Sample #	Date Sampled	Date Received	Lube Time	Unit Time	Lube Change	Lube Added	Filter Change	Fuel Dilution	Soot	Water	Viscosity 40°C	Viscosity 100 °C	Acid Number	Base No. D4739	Oxidation	Nitration
			h	h		gal		%	%	%	cSt	cSt	mg KOH / g	mg KOH / g	abs / cm	abs / 0.1mm
1	N/A	06-May-2024	0	0	Unk	0	Unk	2.0 - GC	0.2 - E2412	<.1 - FTIR		11.0	2.11	3.23	11	9

Particle Count (particles/mL)										Additional Testing	
Sample #	ISO Code	> 4	> 6	> 10	> 14	> 21	> 38	> 70	> 100	Test Method	
	Based On 4/6/14	particles / mL	particles / mL	particles / mL	particles / mL	particles / mL	particles / mL	particles / mL	particles / mL		
1	/ /										

Comments are advisory only and are based on the sample information provided by the customer being valid. Results related only to the items tested. Missing fluid or component information limits the evaluation. No warranty is expressed or implied. Measurement uncertainty available upon request.